

**CR38 – CR 35 to SR 13 Reconstruction
Elkhart County Highway Department**

ADDENDUM NO. 4

December 2, 2022

Item 1: Clarification

Question: How will backfill for pipe trenches be paid for? Can native material be used or will it need to be imported?

Answer: Pipe backfill must meet INDOT requirements for structural backfill. If native material meets INDOT structure fill requirements then it may be used, if it does not then structure backfill will need to be imported. Whether native material or imported material is used, structural backfill will be incidental to the cost of the pipe and will not be paid separately as stated in TP8 of the project specifications.