




Elkhart County Jail
26861 County Road 26
Elkhart, Indiana 46516

Location		Structural Inconsistencies		Recommended Corrections/Modifications to Provide Access	Technical Information			Finalized Actions		
Location	Photo	Identified Issue	ADAAG Specification		Priority Ranking and Justification	Improvement Cost	Funding Source	Finalized Correction	Anticipated Date of Completion	Date of Completion
1. Parking	1	No "Van Accessible" sign at van accessible parking space. No enforcement procedure for accessible parking	4.6.4	ADAAG requires accessible parking spaces to be located in each parking lot. Accessible parking spaces are required to have upright signage that includes the symbol of a accessibility and van accessible signage where required. Add one "Van Accessible" sign. Enforce parking regulations.	L: Space is adequate for vans, just no sign posted.	\$125	Elkhart County General Fund	Sign Installed	2012	Jul-12
2. Registration Counter	2	Registration counter exceeds the maximum height. The counter is 42.5" high.	7.2	ADAAG requires sale and service counters to have a maximum height of 36" above the finished floor. Lower portion of counter or provide auxillary counter at 36" height.	M: Everyone entering facility will use this counter. Employee can walk around counter to communicate.	\$6,000	Elkhart County General Fund			



01. Jail Accessible Parking Signage



02. Jail Front Service Counter