




Department of Public Service

4230 Elkhart Road

Elkhart, Indiana 46526

Location		Structural Inconsistencies		Recommended Corrections/Modifications to Provide Access	Technical Information			Finalized Actions		
Location	Photo	Identified Issue	ADAAG Specification		Priority Ranking and Justification	Improvement Cost	Funding Source	Finalized Correction	Anticipated Date of Completion	Date of Completion
1. Parking		No "Van Accessible" sign at van accessible parking space. No enforcement procedure for accessible parking	4.6.4	ADAAG requires accessible parking spaces to be located in each parking lot. Accessible parking spaces are required to have upright signage that includes the symbol of a accessibility and van accessible signage where required. <b>Add one "Van Accessible" sign. Enforce parking regulations.</b>	<b>L:</b> Space is adequate for vans, just no sign posted.	\$125	Elkhart County General Fund	<b>Sign installed</b>	<b>2013</b>	<b>Jan-15</b>
2. Registration Counter	1,2	Registration counter exceeds the maximum height. The counter is 42 1/2" high.	7.2	ADAAG requires sale and service counters to have a maximum height of 36" above the finished floor. <b>Lower portion of counter or provide auxillary counter at 36" height.</b>	<b>M:</b> Everyone entering facility will use this counter. Employee can walk around counter to communicate.	\$8,000	Elkhart County General Fund			
3. Rest room	3	Lavatory apron exceeds the minimum height. Unit is 27" from floor.	4.19.2	ADAAG requires lavatories to be mounted with the rim or counter surface no higher than 34in above thenished floor and to provide a clearance of at least 29in above the finish floor to the bottom of the apron. <b>Raise the lavatory to provide 29" to finish floor.</b>	<b>L:</b> Pipes and plumbing may need adjusted, which would result in extensive work.	\$700	Elkhart County General Fund			
4. Telephones	4	Public phone does not have appropriate signage for volume control	4.31	ADAAG requires signage identifying that the public telephone has volume control. <b>Install a sign.</b>	<b>L:</b> The phone is in working order with a volume control.	\$50	Elkhart County General Fund	<b>Phone removed</b>		<b>Aug-14</b>



01. Public Services Counters



02. Public Services Counters (2)



03. Public Services Lavatory



04. Public Services Phone