



## Elkhart County Community Corrections

201 N. Cottage Avenue  
Goshen, Indiana 46526


Location		Structural Inconsistencies		Recommended Corrections/Modifications to Provide Access	Technical Information			Finalized Actions		
Location	Photo	Identified Issue	ADAAG Specification		Priority Ranking and Justification	Improvement Cost	Funding Source	Finalized Correction	Anticipated Date of Completion	Date of Completion
1. Parking	1,2	Adequate number of parking spaces are not available.	4.6.1	ADAAG requires parking spaces required to be accessible by 4.1 shall comply with 4.6.2 through 4.6.5. <b>Area needs 4 spaces.</b>	<b>H:</b> Accessible spaces need to be provided.	\$2,000	Elkhart County General Fund	<b>Parking striped</b>		<b>Aug-14</b>
2. Counters	3	Portion of main counter exceeds maximum height of 36 inches. Could walk through a door and come around.	7.2	ADAAG requires a portion of the main counter which is a minimum of 36 inches in length shall be provided with a maximum height of of 36 inches. <b>Provide a lower auxiliary counter or folding shelf. Arrange the counter and surrounding furnishings to create a space to hand items back and forth.</b>	<b>H:</b> Everyone must use this counter. No room to walk around.	\$2,500	Elkhart County General Fund	<b>Remodeled</b>		<b>Jul-18</b>



01. Work Release Parking



02. Work Release Parking (2)



03. Work Release Main Counter